



14 New houses

39 New houses

Blockage: fat, grit, silt, flat pipe, back fall, plan cleanse every 3 months + CCTV

Throttle to be upsized 150mm-300mm as part of the pumping station project about to be promoted

Pipe to be abandoned

Properties to be reconnected

MH1

New MHS

MH SO49672302

Orleton SPS

Pollution

Woofferton SPS

★ Ext flooding

— Proposed solution